



Northeast Laboratories, Inc.

129 MILL STREET • BERLIN, CONNECTICUT 06037-9990
TELEPHONE: 203-828-9787 FAX: 203-829-1050
CT: 1-800-826-0105 OUT OF STATE: 1-800-654-1230

MICROBIOLOGISTS, ANALYTICAL CHEMISTS, ENVIRONMENTAL RESEARCH, CONSULTING SERVICES, PHYSICAL TESTING, FOOD TECHNOLOGY, INDUSTRIAL HYGIENE,
U.S.P.H., F.D.A., E.P.A., AND STATE OF CONNECTICUT APPROVED LABORATORY
MEMBER: AMERICAN INDUSTRIAL HYGIENE ASSOCIATION, AMERICAN WATER WORKS ASSOCIATION
ASSOCIATION OF OFFICIAL ANALYTICAL CHEMISTS, INSTITUTE OF FOOD TECHNOLOGISTS

Town of Enfield
Town Garage
40 Moody Road
Enfield, CT 06082

Attn: Charles L. Cadman, Jr.
cc: Dan Vindigni

Date Received: 3/16/92
Collected: 3/16/92
By: A. C. Johnson
Temp.:
Tested: 3/16-17/92
By: A. C. Johnson
Report: 3/17/92
Lab I.D.: PH0606

CERTIFICATE OF ANALYSIS

Air Sample
Collected: 3/16/92 by A. C. Johnson 4:00 to 5:15 P.M.

Location: Higgins School/Town Hall Annex Basement

Analysis: Fiber Counts

Analytical Method: Phase Contrast Microscopy NIOSH 7400

<u>Sample I.D.:</u>	<u>Sample Location:</u>	<u>Air Volume</u> (liters)	<u>Fibers Longer than 5 Microns</u> (per cc of air)
16EN-01	Inside Room where flooring was removed	540	0.014
16EN-02	Hall outside room (bottom of rear Steps)	530	0.0092
16EN-03	Outside air; front of building	470	0.0021

OSHA Specifications for Fiber Counts:

Greater than 0.10 fibers per cc requires medical surveillance of people working in the area.

Greater than 0.20 fibers per cc requires respiratory protection for people working in the area.

Alan C. Johnson
Director